



DELHI JAL BOARD ;(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT HAIDERPUR,
DELHI-110085



(ISO Certified 9001:2015)

THE TEST REPORT IS
FOR THIS PARTICULAR
WATER SAMPLE ONLY

Water samples collected from:- S1:- DJB Supply (after storage tank), S2:- After Aqua Guard, in the premises of SD Public School, BU- Block, Pitampura, Delhi-110034, vide challan no. 93, dated 05.06.2026.

S. No.	PARAMETERS	UNITS	B.I.S.10500:2012		S1	S2
			Desirable	Permissible		
1.	Date of Collection	--	---	---	-----18.06.2026-----	
2.	Date of Analysis	--	---	---	-----19.06.2026-----	
3.	Colour	C.U.	5	15	1.0	1.0
4.	Odour	--	Agreeable		Agreeable	Agreeable
5.	Turbidity	N.T.U.	1.0	5.0	0.92	0.86
6.	pH value	--	6.5 to 8.5	N.R.	7.75	7.82
7.	Electrical Conductivity	µmhos/cm	---	---	276	275
8.	Total Dissolved Solid	(mg/l)	500	2000	179	179
*	CHEMICAL EXAMINATION					
9.	Phenolphthalein Alkalinity	(mg/l)	---	---	Nil	Nil
10.	Total Alkalinity	(mg/l)	200	600	68	68
11.	Total Hardness	(mg/l)	200	600	120	122
12.	Calcium Hardness	(mg/l)	---	---	81	80
13.	Magnesium Hardness	(mg/l)	---	---	39	42
14.	Calcium as Ca	(mg/l)	75	200	81	80
15.	Magnesium as mg	(mg/l)	30	100	39	42
16.	Ammonia (as NH ₃ -N)	(mg/l)	0.5	N.R.	ND	ND
17.	Nitrite -Nitrogen (N)	(mg/l)	---	---	ND	ND
18.	Nitrate NO ₃	(mg/l)	45	N.R.	1.98	1.76
19.	Sulphate (SO ₄)	(mg/l)	200	400	46	47
20.	Chloride (Cl)	(mg/l)	250	1000	9.8	10
21.	Iron (Fe)	(mg/l)	1.0	N.R.	ND	ND
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.62	0.24
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	ND	ND
24.	Residual Chlorine	(mg/l)	0.2	1.0	1.0	0.40
*	BACTERIOLOGICAL EXAMINATION					
25.	Coli form per 100 ml at 37°C	MPN/100 mL	0		0	0

Remarks: On the basis of tested parameters, water samples 'S1' & 'S2' confirm to drinking water specification IS.10500:2012 and may be used for drinking purpose.

Asstt. Chemist

Chemist/Bacteriologist

A.C.W.A.

PRINCIPAL (Officially)
S.D. PUBLIC SCHOOL
BU- Block, Pitampura
Delhi-110034



NORTH DELHI MUNICIPAL CORPORATION
(Office of the Deputy Health Officer)
PUBLIC HEALTH DEPARTMENT
A-1 BLOCK, KESHAV PURAM ZONE, DELHI-110035

No. DHO/KPZ/2018/ 1296

Dated : 7/12/18

SCHOOL HEALTH CERTIFICATE

Date of Inspection	:	05/12/2018
1. Name of the School	:	S. D. Public School
2. Location	:	BU Block, Pitampura, Delhi - 110034.
3. Timing of School	:	07:50 a.m. to 02:00 p.m.
4. No. of Students	:	Total = 1629 (Boy = 1083 & Girls = 546)
5. No. of Toilet Seats	:	Total = 45 (Male = 23 & Female = 22)
6. No. of Taps	:	102
7. No. of Total Classrooms	:	60

Parameters Checked from Health Point of View

1. Sufficiency of Area	:	The floor area in the classroom is sufficient.
2. Lighting	:	The classes are well lighted.
3. Ventilation	:	The classrooms are well ventilated.
4. Cleanliness	:	The classrooms are kept neat & clean.
5. Requirement of White Wash etc.	:	Building/ Classrooms do not require white wash etc.
6. Drinking Water	:	The drinking water is wholesome.
7. Latrine Arrangement	:	The latrine arrangement is sanitary & hygienic.

In view of the above submissions this Health certificate is being issued in favour of this school by the undersigned, after being fully satisfied and having NO OBJECTION FROM HEALTH POINT OF VIEW.


Dy. Health Officer
Keshav Puram Zone

Dy. HEALTH OFFICER
Keshav Puram Zone
North Delhi Municipal Corporation

The Principal,
S. D. Public School,
BU Block, Pitampura, Delhi-110034.

• Office Copy


PRINCIPAL (Officially)
S.D. PUBLIC SCHOOL
BU-Block, Pitampura
Delhi-110034